

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-25-000393

Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on June 16th, 2025

Applicant	MERMET SAS 58 chemin du Mont Maurin 38630 LES AVENIERES VEYRINS THUELLIN France
SIREN	693620577
Sample reference	ACOUSTIS® 50 M-SCREEN 1 M-SCREEN 3 M-SCREEN 5 SCREEN VISION 1 SCREEN VISION 3 SCREEN VISION 5 SCREEN VISION 10
Brief description provided by the applicant	Canvas made of 36% glass yarn and 64% flame-retardant PVC coating.
Mass per unit area provided by the applicant	350 à 440 g/m ²
Thickness provided by the applicant	0,40 à 0,50 mm
Colour	All colours
End-use condition	Sun protection blind - Interior application

Standard of tests:

- NF P 92-507 (2004) - Building - Interior fitting materials - Classification according to their reaction to fire
- NF P 92-503 (1995) - Reaction to fire tests - Electrical burner test used for flexible materials

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-25-000393-BE from June 20th, 2025.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Saint-Aubin, on June 20th, 2025

Nota. - Full reproductions and photocopies of this English abstract of the official *procès verbal* of classification or the English version of the official *procès verbal* and the attached tests report are authorized.